

§ 3280.806

(ii) For fixed appliances on a circuit without lighting outlets, the sum of rated amperes shall not exceed the branch-circuit rating. Motor loads or other continuous duty loads shall not exceed 80 percent of the branch circuit rating.

(iii) The rating of a single cord and plug connected appliances on a circuit having no other outlets, shall not exceed 80 percent of the circuit rating.

(iv) The rating of the range branch circuit is based on the range demand as specified for ranges in § 3280.811(a)(5). For central air conditioning, see Article 440 of the National Electrical Code, NFPA No. 70-2005.

(v) Where a laundry area is provided, a 20 ampere branch circuit shall be provided to supply laundry receptacle outlets. This circuit shall have no other outlets. See § 3280.806(a)(7).

(b) [Reserved]

[40 FR 58752, Dec. 18, 1975. Redesignated at 44 FR 20679, Apr. 6, 1979, as amended at 58 FR 55020, Oct. 25, 1993; 70 FR 72051, Nov. 30, 2005]

EFFECTIVE DATE NOTE: At 78 FR 73991, Dec. 9, 2013, § 3280.805 was amended by adding a sentence at the end of paragraph (a)(1); revising paragraphs (a)(2) and (a)(3)(i); and adding paragraph (a)(3)(vi), effective June 6, 2014. For the convenience of the user, the added and revised text is set forth as follows:

§ 3280.805 Branch circuits required.

(a) * * *

(1) * * * Lighting circuits are permitted to serve built-in gas ovens with electric service for lights, clocks, or timers, or for listed cord-connected garbage disposal units.

(2) *Small Appliances.* For the small appliance load in kitchens, pantries, dining rooms, and breakfast rooms of manufactured homes, two or more 20-ampere appliance branch circuits, in addition to the branch circuit specified in paragraph (a)(1) of this section, must be provided for all receptacle outlets in these rooms, and such circuits must have no other outlets. Countertop receptacle outlets installed in the kitchen must be supplied by not less than two small appliance branch circuits. One or more of the small appliance branch circuits may also supply other receptacle outlets in the kitchen, pantry, dining room, and breakfast room. Receptacles installed solely for the electrical supply to an electric clock and receptacles installed to provide power for supplemental equipment and lighting on gas-fired ranges, ovens, or counter-mounted cooking units are not subject to the requirements of this paragraph (a)(2).

(3) * * *

24 CFR Ch. XX (4-1-14 Edition)

(i) The ampere rating of fixed appliances must not exceed 50 percent of the circuit rating if lighting outlets are on the same circuit (receptacles in the kitchen, dining area, and laundry are not considered to be lighting outlets);

* * * * *

(vi) Bathroom receptacle outlets must be supplied by at least one 20-ampere branch circuit. Such circuits must have no other outlets, except that it is permissible to place the receptacle outlet for a heat tape or pipe heating cable required by § 3280.806(d)(10) on a bathroom circuit. (See § 3280.806(b).)

* * * * *

§ 3280.806 Receptacle outlets.

(a) All receptacle outlets shall be:

(1) Of grounding type;

(2) Installed according to Article 406.3 of the National Electrical Code, NFPA No. 70-2005.

(3) Except when supplying specific appliances, be parallel-blade, 15-ampere, 125-volt, either single or duplex.

(b) All 120 volt single phase, 15 and 20 ampere receptacle outlets, including receptacles in light fixtures, installed outdoors, in compartments accessible from the outdoors, in bathrooms, and within 6 feet of a kitchen sink to serve counter top surfaces shall have ground-fault circuit protection for personnel. Feeders supplying branch circuits may be protected by a ground-fault circuit-interrupter in lieu of the provision for such interrupters specified above. Receptacles dedicated for washer and dryers, also located in a bathroom, are exempt from this requirement.

(c) There shall be an outlet of the grounding type for each cord-connected fixed appliance installed.

(d) Receptacle outlets required. Except in the bath and hall areas, receptacle outlets shall be installed at wall spaces 2 feet wide or more, so that no point along the floor line is more than 6 feet, measured horizontally, from an outlet in that space. In addition, a receptacle outlet shall be installed:

(1) Over or adjacent to counter tops in the kitchen (at least one on each side of the sink if counter tops are on each side and 12 inches or over in width).

(2) Adjacent to the refrigerator and free-standing gas-range space. A duplex

receptacle may serve as the outlet for a countertop and a refrigerator.

(3) At counter top spaces for built-in vanities.

(4) At counter top spaces under wall-mounted cabinets.

(5) In the wall, at the nearest point where a bar type counter attaches to the wall.

(6) In the wall at the nearest point where a fixed room divider attaches to the wall.

(7) In laundry areas within 6 feet of the intended location of the appliance(s).

(8) At least one receptacle outlet shall be installed outdoors.

(9) At least one wall receptacle outlet shall be installed in bathrooms within 36 inches (914 mm) of the outside edge of each basin. The receptacle outlet must be located on a wall that is adjacent to the basin location. This receptacle is in addition to any receptacle that is part of a lighting fixture or appliance. The receptacle must not be enclosed within a bathroom cabinet or vanity.

(10) Receptacle outlets are not required in the following locations:

(i) Wall space occupied by built-in kitchen or wardrobe cabinets,

(ii) Wall space behind doors which may be opened fully against a wall surface,

(iii) Room dividers of the lattice type, less than 8 feet long, not solid within 6 inches of the floor,

(iv) Wall space afforded by bar type counters.

(e) Receptacle outlets shall not be installed in or within reach (30 inches) of a shower or bathtub space.

(f) Receptacle outlets shall not be installed above electric baseboard heaters.

[40 FR 58752, Dec. 18, 1975. Redesignated at 44 FR 20679, Apr. 6, 1979, as amended at 58 FR 55020, Oct. 25, 1993; 70 FR 72052, Nov. 30, 2005]

EFFECTIVE DATE NOTE: At 78 FR 73991, Dec. 9, 2013, § 3280.806 was amended by revising paragraphs (b) and (d) introductory text; redesignating paragraph (d)(10) as (d)(11) and adding a new paragraph (d)(10) and paragraph (g), effective June 6, 2014. For the convenience of the user, the added and revised text is set forth as follows:

§ 3280.806 Receptacle outlets.

* * * * *

(b) All 125-volt, single-phase, 15- and 20-ampere receptacle outlets installed outdoors, or in compartments accessible from outside the manufactured home, and in bathrooms, including receptacles in light fixtures, must have ground-fault circuit-interrupter protection for personnel. Ground-fault circuit-interrupter protection for personnel must be provided for receptacles serving countertops in kitchens and receptacle outlets located within 6 feet of a wet bar sink, except for receptacles installed for appliances in dedicated spaces, such as dishwashers, disposals, refrigerators, freezers, and laundry equipment.

* * * * *

(d) *Receptacle outlets required.* Except in the bath, closet, and hall areas, receptacle outlets must be installed at wall spaces 2 feet or more wide, so that no point along the floor line is more than 6 feet, measured horizontally, from an outlet in that space. Receptacle outlets in floors shall not be counted as part of the required number of receptacle outlets, unless located within 18 inches of the wall. In addition, a receptacle outlet must be installed in the following locations:

* * * * *

(10) On the underside of the home for the connection of pipe heating cable(s) or heat tape(s), and the outlet must:

(i) Be located within 2 feet of the cold water inlet;

(ii) Be connected to an interior branch circuit, other than a small appliance branch circuit;

(iii) Be located on a circuit where all of the outlets are on the load side of the ground-fault circuit-interrupter protection for personnel; and

(iv) Not be considered as the receptacle outlet required by paragraph (8) of this section.

* * * * *

(g) Receptacles must not be in a face-up position in any countertop.

§ 3280.807 Fixtures and appliances.

(a) Electrical materials, devices, appliances, fittings, and other equipment installed, intended for use in, or attached to the manufactured home shall be approved for the application and shall be connected in an approved manner when in service. Facilities shall be